Form ED-B-42
REV. 9/24/70
REV. 6/1/73

# LIST OF CORRECTIONS

~~RETROACTIVE~~
~~RESIDENTIAL~~
~~BUSINESS~~

~~ARTICLE 6 SECTIONS 640.0 THROUGH 649.0 1972 D.C. BUILDING CODE~~

L-2

| Address of Premises requiring Corrections | USE | Book No. | File Reference | Typist |
|---|---|---|---|---|
| 3765 N. Hampton St., N. W. | Community /Residence | | | jbj |
| Name of Owner or Agent | Name of Inspector | | Date of Inspection | |
| | James Minor | | 6/6/79 | |

IN ACCORDANCE WITH THE NOTICE WITH WHICH THIS LIST IS SENT TO YOU AND THE "STATEMENT OF INTENT AND ADMINISTRATIVE PROCEDURES" WHICH BEGINS WITH ARTICLE 6 SECTION 640.0 1972 D.C. BUILDING CODE, YOU MUST CORRECT NON-CONFORMING CONDITIONS REVEALED BY THE INSPECTION AT THE ABOVE ADDRESS. EACH "X" IN A NUMBERED BOX BELOW INDICATES A DESCRIPTION OF WORK TO CORRECT PART OR ALL OF THE DEFICIENCIES OF THE PREMISES UNDER THE CITED SECTIONS OF THE BUILDING CODE (CITATIONS UNDERLINED). IGNORE PARAGRAPHS NOT PRECEDED BY AN "X" IN THE CHECK BOX. FURTHER INFORMATION MAY BE OBTAINED FROM THE CONSTRUCTION SECTION BETWEEN 8:15 AM and 4:45 PM, MONDAY THROUGH FRIDAY, TELEPHONE: 629-3712

| SURVEY ITEM NO. | | DESCRIPTION OF WORK AND CODE CITATION |
|---|---|---|
| 2 | ☐ | ENCLOSE ALL STAIRS WITH FIRE-PROTECTED PARTITIONS AND SELF-CLOSING FIRE DOORS, PROVIDE VENTILATION. 641.8 |
| 2a | ☐ | NON-EGRESS OR 2ND STAIRS ARE REQUIRED TO BE ENCLOSED ON ALTERNATE FLOORS. 641.8 |
| 3 | ☐ | REARRANGE ALL EGRESS STAIRS TO OPEN EITHER DIRECTLY ON A STREET OR PUBLIC ALLEY OR ON AN OPEN AIR OR FIRE-RESISTIVE PASSAGE LEADING THERETO. FOR STAIRS DISCHARGING THROUGH A LOBBY OR FOYER SEE 617.5; 643.4 |
| 4 | ☐ | PROVIDE HANDRAILS ON ALL STAIRS. 641.5 |
| 5 | ☒ | PROVIDE TWO APPROVED MEANS OF EGRESS FOR EACH ROOM OR SUITE OF ROOMS ON ALL FLOORS. 643.2 |
| 6 | ☐ | PROVIDE ACCESS TO THE ROOF. 641.2 |
| 7 | ☐ | FIRE-PROTECT OR REMOVE ALL CLOSETS UNDER STAIRS OR IN STAIR ENCLOSURES. 641.6 (2) |
| 8 | ☐ | FIRE-PROTECT CORRIDOR PARTITIONS AND CEILINGS. 641.12 |
| 9 | ☐ | PROVIDE SELF-CLOSING FIRE DOORS BETWEEN ROOMS AND EXIT CORRIDORS OR PASSAGES. 641.11 |
| 10 | ☐ | PROVIDE FIRE DOORS BETWEEN ROOMS AND PUBLIC CORRIDORS. 641.11 |
| 12 | ☒ | TERMINATE BASEMENT STAIRS – TOP OR BOTTOM – WITH 45-MINUTE FIRE RATED PARTITIONS AND SELF-CLOSING FIRE DOORS. 641.8; 641.13 (1) |
| 13 | ☒ | FIRE-PROTECT ENTIRE BASEMENT CEILING WITH APPROVED MATERIAL. 641.13 (1) |
| 15 | ☒ | FIRE-PROTECT ALL DOORS AND WINDOWS OPENING ONTO OR WITHIN TEN FEET UNDER OUTSIDE FIRE ESCAPES AND EXTERIOR SCREENED STAIRS. 641.7 (2) |

| SURVEY ITEM NO. | | DESCRIPTION OF WORK AND CODE CITATION |
|---|---|---|
| 16 | ☐ | EXTEND FIRE ESCAPES TO THE ROOF. 641.5 |
| 17 | ☒ | SWING EXIT DOORS AS REQUIRED IN, IN THE DIRECTION OF EXIT TRAVEL. EXIT DOORS SHALL NOT SWING BEYOND THE BUILDING LINE EXCEPT AS PERMITTED IN 641.11 (5) (6) |
| 18 | ☐ | INSTALL FIRE EXTINGUISHERS OF SUCH TYPES AND IN SUCH LOCATIONS AS REQUIRED BY THE FIRE MARSHAL AND BY 642.3 |
| 19 | ☐ | INSTALL AN APPROVED FIRE ALARM SYSTEM 642.4; 1203.1 |
| 20 | ☐ | INSTALL AN APPROVED PLACARD AT EACH FIRE ALARM STRIKING STATION STATING WHETHER THE ALARM SYSTEM IS OR IS NOT CONNECTED TO THE MUNICIPAL FIRE ALARM SYSTEM 642.1; 1203.13 |
| 21 | ☐ | INSTALL EMERGENCY LIGHTS, LIGHTED DIRECTIONAL SIGNS AND EXIT SIGNS AS REQUIRED ALONG APPROVED EXIT TRAVEL PATHS 613.0; 642.1 |
| 25 | ☒ | SUBMIT TO THE DEPARTMENT OF LICENSES AND INSPECTIONS SUCH PLANS AS REQUIRED TO SHOW EXISTING CONDITIONS AND PROPOSED CONSTRUCTION 107.9 |
| 27 | ☐ | CLOSE UP OR REMOVE ALL TRANSOMS BETWEEN ROOMS AND PUBLIC OR EXIT CORRIDORS AND LOBBIES 641.13 |
| 28 | ☐ | ENCLOSE ALL ELEVATOR, DUMBWAITER, PIPE AND VENT SHAFTS 641.10; 909.0 |
| 30 | ☐ | PROPERLY MAINTAIN STANDPIPE SYSTEM 642.5 |
| 32 | ☐ | REVOLVING DOORS SHALL CONFORM TO 641.11 (2) |
| | ☐ | |

PERMITS

☐ ARE NOT REQUIRED FOR THE ABOVE WORK

☒ ARE REQUIRED AS FOLLOWS: Construction

CONSTRUCTION INSPECTION SECTION, BUILDING DIVISION Department of Economic Development, Rm. LL-16 – 614 H Street, NW 20001

2553

Form ED-B-8
Rev. 9/24/70

# COMPOSITE NOTICE OF DEFICIENCIES

TO BE CORRECTED PRIOR TO ISSUANCE OF CERTIFICATE OF OCCUPANCY

~~ARTICLES, SECTIONS 640.1 THROUGH 640.20, 1972 EDITION OF THE BUILDING CODE~~

3765 N. Hampton Street, N. W.
Washington, D. C.

DATE: June 7, 1979

FILE NO.:

BOOK NO.:

PROPOSED USE: Community Residence

DEFICIENCY LISTS ARE ATTACHED AS INDICATED (X)

| CODE OR REGULATION | TITLE OF FORM |
|---|---|
| [ ] HOUSING | LIST OF DEFICIENCIES |
| [ ] PLUMBING & REFRIG. | PLUMBING DEFICIENCY NOTICE |
| [ ] ELECTRICAL | ELECTRICAL DEFECTIVE NOTICE |
| [X] BUILDING | (LIST attached or typed below) |

PREMISES ADDRESS (Omitted if same as above)

3765 N. Hampton St., N. W.

THIS DOES INCLUDE ANY DEFICIENCIES WHICH MAY BE SENT BY THE HOUSING DIVISION.

THIS WORK SHALL BE COMPLETED WITHIN 30 DAYS FROM DATE OF RECEIPT OF THIS NOTICE.

The premises named in your application for a Certificate of Occupancy have been inspected for compliance with the applicable codes and regulations. Lists attached to (or typed on) this form indicate CORRECTIVE ACTIONS WHICH YOU MUST COMPLETE BEFORE YOUR CERTIFICATE OF OCCUPANCY MAY BE ISSUED.

SIGNATURE: James W. Harris
James W. Harris

CHIEF CONSTRUCTION
CONSTRUCTION INSPECTION SECTION

JWH/jbj

CONSTRUCTION INSPECTION SECTION, BUILDING DIVISION,
Dept. of Housing & Comm. Development, Rm LL-16, 614 H St., N.W. 20001

J-63908—76